

LDWBF
12.3.412.1
11-3-98

02/22/1999 10:20 425-338-9749

NW TANK

PAGE 02

RECEIVED

NOV 4 1998

LONG PAINTING CO

Puget Sound Air Pollution Control Agency

Registration No. 10015

Notice of
Construction No. 7623

Date NOV 3 1998

HEREBY ISSUES AN ORDER OF APPROVAL
TO CONSTRUCT, INSTALL, OR ESTABLISH

Stage 1 & 2 vapor recovery using Two Point System on one 10,000 gallon underground gasoline storage tank, and 2 OPW11VAI-(63, 68, 83 or 88) Nozzles with Vapor Valve and Efficiency Compliance Device (ECD) on a Gasboy VaporEZ Vacuum Assist Style Dispenser; equipment and installation as per CARB Executive Orders G-70-97-A (Stage 1) and G-70-163-AA (Stage 2).

KAREN SAY

A
P
P
L
I
C
A
N
T

SAYBR CONTRACTORS INC

17803 51ST AVE S

SEATTLE

WA 98188

O LONG PAINTING CO

W
N
E
R

PO BOX C-81435

SEATTLE

WA 98108-4498

INSTALLATION ADDRESS

LONG PAINTING CO, 8025 10TH AVE S, SEATTLE, WA, 98108

THIS ORDER IS ISSUED SUBJECT TO THE FOLLOWING RESTRICTIONS AND CONDITIONS

1. Approval is hereby granted as provided in Article 6 of Regulation I of the Puget Sound Air Pollution Control Agency to the applicant to install or establish the equipment, device or process described hereon at the INSTALLATION ADDRESS in accordance with the plans and specifications on file in the Engineering Division of PSAPCA.
2. This approval does not relieve the applicant or owner of any requirement of any other governmental agency.
3. Prior to placing the above equipment into operation, the applicant or owner shall certify compliance with the CARB approval order including a pressure decay (CARB test procedures in Exhibit 3 of Executive Order G-70-163-AA, adopted September 4, 1996), back pressure (wet CARB test procedure TP-201.4, adopted April 12, 1996) and air to liquid ratio (CARB test procedure TP-201.5, adopted April 12, 1996) tests. The results of the equipment installation certification tests shall be submitted to PSAPCA within 30 days of equipment startup.

APPEAL RIGHTS

Pursuant to PSAPCA's Regulation I, Section 3.17 and RCW 43.21B.310, this Order may be appealed to the Pollution Control Hearings Board (PCHB). To appeal to the PCHB, a written notice of appeal must be filed with the PCHB and a copy served upon PSAPCA within 30 days of the date the applicant receives the Order.

USEPA SF



1410134

LARRY C. VAUGHN
Reviewing Engineer

MEJ

JAY M. WILLENBERG
Reviewing Engineer

DENNIS J. McLERRAN
Air Pollution Control Officer

LP_00970